



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 7/17/09

Code 50.10.5-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – Dashed line through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

Code Title 2009 Indiana Residential Code		Edition First Edition
Section number and title R604.3 Installation		Page 1 of 1
Proponent Craig Wagner	Title Chief Building Inspector/ IABO Code Comm. Member	
Address 220 W Van Buren St, Columbia City IN 46725		Phone 260-248-3111
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input checked="" type="checkbox"/> Delete without substitution		
Delete the last sentence of Section R604.3 without substitution.		
REASON AND FISCAL IMPACT		
This sentence was deleted out of the 2005 InRC because the committee felt that leaving it in would allow masonry veneer to be installed over the panels without a weather barrier and thus allow panel wetting and mold formation.		
Fiscal impact: there is no increase to the cost of construction.		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		

